CITY OF FORT LAUDERDALE

UNSAFE STRUCTURES BOARD AGENDA

AUGUST 18, 2011

3:00 PM

COMMISSION MEETING ROOM CITY HALL

100 N. ANDREWS AVENUE

UNSAFE STRUCTURES BOARD

Ordinance: C-75-26

PURPOSE: To establish uniform minimum standards for the occupancy of dwelling, hotel and rooming structures and for the uniform minimum standards for the maintenance of the premises occupied or adjacent to such structures, including vacant lots and the premises of business establishments located in proximity thereto.

If any person decides to appeal any decision made with respect to any matter considered at this public meeting or hearing he/she will need a record of the proceedings and for such purpose, he/she may need to ensure that a verbatim record of the proceedings is made, which record includes the testimony and evidence upon which the appeal is to be based.

Board Members: John Scherer, **Chair •** John Phillips, **Vice Chair •** John Barranco • Joe Crognale •Pat Hale • Joe Holland • Thornie Jarrett • Michael Weymouth• Don Larson

TWO OR MORE FORT LAUDERDALE CITY COMMISSIONERS OR MEMBERS OF A CITY OF FORT LAUDERDALE ADVISORY BOARD MAY BE IN ATTENDANCE AT THIS MEETING.

COMMUNICATION TO THE CITY COMMISSION WILL BE ADDRESSED AT THE END OF THE HEARING.

Page 1

CITY OF FORT LAUDERDALE AGENDA

UNSAFE STRUCTURES BOARD CITY COMMISSION ROOM - CITY HALL

AUGUST 18, 2011 3:00 PM

HEARING SCHEDULED

.-----

CASE NO: CE11011181 CASE ADDR: 1700 SW 9 ST

OWNER: WEAVER, RICHARD L EST

INSPECTOR: GERRY SMILEN

VIOLATIONS: FBC(2007) 115.1.1

THE SINGLE FAMILY DWELLING HAS BEEN SUBSTANTIALLY DAMAGED BY THE ELEMENTS HAS BECOME A WINDSTORM

HAZARD.

FBC(2007) 115.2.1.1.1

THE BUILDING IS OPEN AT THE FRONT DOOR, VACANT AND

ABANDONED.

FBC(2007) 115.2.1.2.1

THE FOLLOWING BUILDING COMPONENTS ARE

LOOSE, HANGING OR LOOSENING:

ROOF DECKING.

ROOF RAFTERS.

FASCIA BOARD.

STUCCO.

SOFFIT OVERHANGS.

TAR AND GRAVEL ROOFING MATERIAL.

FRONT WALL.

PAINT.

FBC(2007) 115.2.1.2.2

THE RAFTERS, ROOF DECKING AND ROOFING MATERIAL ARE DETERIORATING DUE TO LACK OF MAINTENANCE AND

EXPOSURE TO THE ELEMENTS.

FBC(2007) 115.2.1.2.4

THE FOLLOWING BUILDING COMPONENTS ARE LEANING OUT OF PLUMB OR SAGGING:

- 1. ROOF RAFTERS
- 2. EXTERIOR WALLS.

Page 2

AGENDA

CITY OF FORT LAUDERDALE AGENDA

UNSAFE STRUCTURES BOARD CITY COMMISSION ROOM - CITY HALL

AUGUST 18, 2011 3:00 PM

CASE NO: CE11011268
CASE ADDR: 1860 SW 37 WY
OWNER: ROBINSON,LINDA
INSPECTOR: JORG HRUSCHKA

VIOLATIONS: FBC(2007) 115.1.1

THE ORIGINAL CARPORT WAS ILLEGALLY ENCLOSED. THE

STRUCTURAL COMPONENTS OF THE ENCLOSURE ARE SEVERELY DETERIORATED AND ARE NOW A WINDSTORM HAZARD. OTHER LEAN TO STYLE STRUCTURES WERE ADDED

IN THE REAR.

FBC(2007) 115.1.3

THE STRUCTURES ARE UNSAFE AND MUST BE DEMOLISHED

OR MADE SAFE.

FBC(2007) 115.2.1.2.1

THE STRUCTURAL ROOF, SIDING AND WALL COMPONENTS

ARE HANGING LOOSE.

FBC(2007) 115.2.1.2.2

THE STRUCTURAL WALL AND ROOF COMPONENTS ARE

SEVERERLY DETERIORATED.